

GOVERNMENT OF WEST BENGAL

Office of the Divisional Fire Officer, D2 Division
West Bengal Fire & Emergency Services
C.R. Das Road, Berhampore, Murshidabad.

Memo no. FES/D2/270 / 11

Dated ...12.5.2011.

From : The Divisional Fire Officer, D2 Division,
W.B. Fire & Emergency Services
Berhampore, Murshidabad.

To : Smt. Rebeka Das
Secretary, Maa Manasha Primary Teachers Training Institute (D.ED)
Vill – Kanralia, P.O. Balidanga Faridpur,
P.S. Kaligunj, Dist. Nadia.

Sub : Provisional N.O.C. in Favour of proposed (G+2) (D.ED) College
building named Maa Manasha Primary Teachers Training Institute
(D.ED).

There is no objection from Fire Service point of view to issue provisional N.O.C. in favour of MAA Manasha Primary Teachers Training Institute. Three storied building on the Plot no. 239, 240, 241, 753, 754, Khatian No. L.R. 914 J.L. No. 94 Mouza – Kanralia under P.S. Kaligunj, Dist. Nadia. Subject to fulfillment the following recommendations.

RECOMMENDATIONS :-

A. (1) The whole construction of the building shall be carried out as per approved plan drawing confirming the relevant rule of Local Panchayet Body as well as N.B.C. of India 2005.

- (2) The floor area exceeds 1874.5 sq. mts. Shall be sweetably compartmented by separation walls upto ceiling level having 2 hours fire resistance capacity.
- (3) The interior finish decoration of the building shall be made low flame spread materials confirming I.S. specification.
- (4) Provision of ventilation of the crown of central code duct of the building shall be provided.
- (5) Arrangement shall have to be made for sealing all the vertical ducts by the materials of adequate Fire resistance capacity.

B. OPEN SPACE & APPROACH ROAD :

- (1) The open space of the surrounding building shall confirming the relevant building rules as well as to permit the accessibility and manuverability of Fire appliances with turning facility.
- (2) The approach road shall be sufficiently strong to with stand the load of fire engine weighting to 20 mt.
- (3) The width and height of the access gates into the premises shall not be less than 4.5 mtr. & 5 mtr. Respectively by abounding the road.

C. STAIR CASES :-

- (1) The stair case of the building shall be enclosed type, entire construction shall be made brick/RCC type having fire resistance not less than 4 hrs.
- (2) The staircase of the building shall have permanent vents at the top and openable sashes at each floor level in the external wall of the building.

P.T.O.