


- (3) All the stair cases shall be extended up to tarace of the building and shall be negotiable to each other without entering into any room.
- (4) Another stair case should be made at the south side of the building for the safety of the students and other. Staircase shall be made as per N.B.C. (Part IV) of India.
- (5) For existing building a certificate obtain from the appropriate authority regarding constructional safety point of view as well as clearance certificate for electrical installation, fittings if any.
- (6) Underground reservoir having capacity 20,000 lts. Always kept free from all obstruction.
- (7) Provision of standard Hose Real Hose supplied water from overhead reservoir (capacity 10,000 Lts.) through down corner will have to made in all the floor of the building to satisfying the code of I.S. specification 3844-1989. The system will be adopted in each floor by installing minimum 4 nos. Hose real Hose positively. By the constructional method for fire prevention and protection.
- (8) First Aid Fire fighting system :- First Aid fire fighting arrangement in the style of placing suitable type fire extinguisher, fire bucket etc. In all floor in visible location of the building shall be install in accordance with I.S. 2190 – 1992.
- (9) **General Recommendation** :- All the extinguishers should be tested at least once in a year by an authorise agency and certificate shall be pasted on the body of the extinguisher.
- (10) Fire licence shall have obtained in case of storing & processing with L.P.G. & other highly combustibile article if any.
- (11) No cooking arrangement should be made in the college building.
- (12) All the teachers and non-teaching staff should have knowledge to operate fire fighting equipments and awareness of fire.
- (13) After completion of the all fire safety installation of building a letter of intimation must be submitted to this office for final inspection to issue the final N.O.C. of the building.
- (14) Violation of any recommendation mention above legal action will be taken as per fire service act 1950 (upto date amendment) and the provisional N.O.C. shall be treated as cancel.


**Divisional Fire Officer,
D2 Division,
W.B. Fire & Emergency Services,
Berhampore, Murshidabad.**